



### TEST REPORT

Sample Number : SN-001/22-2445  
Report Number : AISL-RP-22-3587  
Report Date : 17/02/2022

Customer	Name	: Millennium Environmental Services
	Address and Location	: P.O Box 38806, Abu Dhabi UAE
Project No	: Not specified	
Project Name	: Not specified	
Project Location	: Al Ain	
Client	: Al Saad Indian School	
Sample Description	: Tank Water	
Sampling Method	: APHA 9060 A 23rd Edition, 2017	Sampled By : AISL Rep
Sample Delivered By	: AISL Rep	Client Ref.No : Not specified
Date of Analysis	: 13/02/2022~ 15/02/2022	Test Conducted By : JUD
Brand	: Not specified	Sampling Date/Time : 13/02/2022 12:30 PM
Origin	: Roof Top Water Tank - GRP Tank	Receiving Date/Time : 13/02/2022 03:00 PM
Net wt./volume per unit	: 500 ml	Production Date : Not specified
No. of Unit	: 01	Expiry Date : Not specified
Packaging Type	: Sterile Bottle	Condition of Sample °C : 23.2
Physical Observations	: Satisfactory	

### TEST RESULTS

#### MICROBIOLOGICAL ANALYSIS

PARAMETERS	TEST METHODS	UNITS	RESULTS	SPECIFICATIONS
E. coli	APHA AWWA 23rd Ed.2017, 9222B&H	CFU/100ml	Absent	Absent
Fecal Coliforms	APHA AWWA 23rd Ed. 2017, 9222D	CFU/100ml	Absent	Absent
Heterotrophic Plate Count	APHA AWWA 23rd Ed. 2017, 9215B	CFU/ml	26	-
Enterococci	APHA AWWA 23rd Ed. 2017, 9230 C	CFU/100ml	Absent	Absent
Total Coliforms	APHA AWWA 23rd Ed. 2017, 9222B	CFU/100ml	Absent	Absent

Remarks : None  
Test Method Deviation : None  
Reference Specification : Department of Energy, Water Quality Regulations 2021.

Approved by Arun-Bahulayan  
Section Head - Microbiology



For Microbiology Parameter Results "<" symbol is considered as "Not Detected"

(-) Denotes no limit available

If sampled by client, details of sampling which may affect the accuracy of the test result were not provided.

This report relates only to the sample tested and shall only be reproduced in full and with the written approval of Aman integrated solutions LLC.

AISL/MB/RP-06, Issue No/04.07.2021, Rev No:00

-End Of Report-

Attested

Khalifa Industrial Zone A8, P.O.Box: 44626, Abudhabi, United Arab Emirates

Tel: +971 22361388, Fax: +971 2 6767566, Email : lab@amanis.ae, Website: www.amanis.ae

PRINCIPAL

AL SAAD INDIAN SCHOOL  
AL-AIN, UAE